

# PRODUCT DATA SHEETS

## Base Grille Water Filtration System System Model WF-L200V/Replacement Filter EDR6D1 (equivlent to L200V)

Capacity 200 Gallons (757 Liters)

## System Model WF-NL120V/ Replacement Filter EDR6D1 (equivlent to L200V)

Capacity 120 Gallons (454 Liters)



System tested and certified by NSF International against NSF/ANSI Standard 42, 53 and CSA B483.1 for the reduction of contaminants specified on the Performance Data Sheet.

This system has been tested according to NSF/ANSI 42, 53 and CSA B483.1 for the reduction of the substances listed below. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system, as specified in NSF/ANSI 42, 53 and CSA B483.1.

Substance Reduction Aesthetic Effects	Influent Challenge Concentration	Maximum Permissible Product Water Concentration	Average% Reduction
Chlorine Taste/Odor	2.0 mg/L ± 10%	≥50%	>97.4%
Particulate Class I*	At least 10,000 particles/mL	≥85%	99.3%
Contaminant Reduction	Influent Challenge Concentration	NSF Reduction Requirements	Average% Reduction
Lead: @ pH 6.5	0.15 mg/L ± 10%	0.01mg/L	>99.7%
Lead: @ pH 8.5	0.15 mg/L ± 10%	0.01mg/L	>99.7%
Mercury: @ pH 6.5	0.006 mg/L ± 10%	0.002 mg/L	96.5%
Mercury: @ pH 8.5	0.006 mg/L ± 10%	0.002 mg/L	95.2%
Benzene	0.015 mg/L± 10%	0.0050 mg/L	>96.7%
Ethylbenzene	2.1 mg/L ±10%	0.7 mg/L	>99.9%
p-dichlorobenzene	0.225 mg/L ± 10%	0.075 mg/L	>99.7%
O-Dichlorobenzene	1.8 mg/L ±10%	0.6 mg/L	99.9%
Toxaphene	0.015 mg/L ±10%	0.003 mg/L	>93.7%
1,2,4-Trichlorobenzene	0.21 mg/L ±10%	0.07 mg/L	>99.7%


Test Parameters: pH = 7.5 ± 0.5 unless otherwise noted. Flow = 0.5 gpm (1.9 Lpm). Pressure = 60 psig (413.7 kPa). Temp. = 63°F (17.2°C).

- It is essential that operational, maintenance, and filter replacement requirements be carried out for the product to perform as advertised.
- Model WF-L200V:** The filter monitor system measures the amount of water that passes through the filter and alerts you to replace the filter. When 90% of the filter's rated life is used, the filter indicator light changes from green to yellow. When 100% of the filter's rated life is used, the filter indicator light changes from yellow to red, and it is recommended that you replace the filter. Use replacement cartridge EDR6RD1 (equivalent to 200V, NL120V, #4396702). 2015 suggested retail price of \$49.99 U.S.A./\$49.99 Canada. Prices are subject to change without notice.
- Model WF-NL120V:** Change the water filter cartridge every 6 months. Use replacement cartridge EDR6RD1, (equivalent to 200V, NL120V, #4396702). 2015 suggested retail price of \$49.99 U.S.A./\$49.99 Canada. Prices are subject to change without notice.
- The product is for cold water use only.
- Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system.
- Refer to the front cover or "Accessories" section for the Manufacturer's name, address and telephone number.
- Refer to the "Warranty" section for the Manufacturer's limited warranty.

### Application Guidelines/Water Supply Parameters

Water Supply	Potable City or Well
Water Pressure	30 - 120 psi (207 - 827 kPa)
Water Temperature	33° - 100°F (0.6° - 37.8° C)
Service Flow Rate	0.5 GPM (1.89 L/min.) @ 60 psi.

- Your water filtration system will withstand up to 120 pounds per square inch (psi) water pressure. If your water supply is higher than 80 psi, install a pressure reducing valve before installing the water filtration system.



\*Class I particle size: ≥0.5 to < 1.0 μm

\*\*Test requirement is at least 10,000 particles/mL of AC Fine Test Dust.

\*\*\*These contaminants are not necessarily in your water supply.

Performance may vary based on local water conditions.

© NSF is a registered trademark of NSF International.